

STONINGTON PUBLIC SCHOOLS

40 FIELD ST., PAWCATUCK, CT 06379

PHONE: (860) 572-0506

FAX: (860) 599-8948



BOARD OF EDUCATION: Alexa J. Garvey, Chair; Candace Anderson, Secretary

SUPERINTENDENT
Van W. Riley, Ph.D.

ASSISTANT SUPERINTENDENT
Mary Anne Butler

DIRECTOR OF SPECIAL SERVICES
Allison Van Etten

DIRECTOR OF FINANCE
Gary J. Shettle

Pawcatuck Middle School renovation

Addendum #2

Attached please find Addendum #1 to the Pawcatuck Middle School Renovation Specifications for the Stonington Public Schools which has a bid Due date of January 21, 2020. This addendum is two pages (including this cover page). **Please acknowledge your receipt of this addendum by signing this cover memo in the space provided below and submitting this acknowledgement with your Proposal documents on January 21, 2020.**

We appreciate your participation in this exciting contracting opportunity.

ACKNOWLEDGMENT:

Addendum #2 was received:

BY: _____ (Company Name)

NAME TITLE: _____

SIGNATURE: _____

DATE: _____



AIR CONDITIONER SCHEDULE

SYMBOL	MANUFACTURER MODEL NUMBER	TYPE	AREA SERVED	CFM	COOLING CAPACITY BTUH	SENSIBLE COOLING CAPACITY BTUH	ELECTRICAL VOLTS/PH/Hz	MCA	WEIGHT (LBS)	NOTES
FC1-1	DAIKIN FAG24TAJU	DX	SERVERS	635	24000	18000	208-230/1/60	.5	31	2,3,5
HP1-1	DAIKIN RZR24TAJU	DX	FC1	2652	24000	18000	208-230/1/60	16.5	172	1,4

TYPES:

DX = DIRECT EXPANSION 4410A

NOTES:

1. PROVIDE LOW AMBIENT COOLING AND WIND BATTERIES TO 0 DEGREES F.
2. PROVIDE LOW AMBIENT COOLING AND WIND BATTERIES TO 0 DEGREES F.
3. PROVIDE MANUFACTURER RECOMMENDED THERMOSTAT.
4. PROVIDE HOUSEKEEPING PAD.
5. PROVIDE CONDENSATE PUMP.

AIR CONDITIONER/HEAT PUMP SCHEDULE

SYMBOL	MANUFACTURER MODEL NUMBER	TYPE	AREA SERVED	CFM	COOLING CAPACITY BTUH/ SENSIBLE	HEATING CAPACITY BTUH	ELECTRICAL VOLTS/PH/Hz	MCA	WEIGHT (LBS)	NOTES
FC2-1	DAIKIN FXZ018TAJU	DX 2X2 CEILING CASSETTE	IT CENTRAL HUB	441	18,000/ 13,000	20,000	208-230/1/60	0.6	40.8	1,2
FC3-2	DAIKIN FXZ007TAJU	DX 2X2 CEILING CASSETTE	AEA OFF-2	247	5,800/ 7,500	6,500	208-230/1/60	0.3	34.2	1,2
FC3-3	DAIKIN FXZ007TAJU	DX 2X2 CEILING CASSETTE	AEA OFF-3	300	5,800/ 7,500	6,500	208-230/1/60	0.3	34.2	1,2
FC3-4	DAIKIN FXZ007TAJU	DX 2X2 CEILING CASSETTE	AEA OFF-4	247	5,800/ 7,500	6,500	208-230/1/60	0.5	34.2	1,2
FC7-4	DAIKIN FXZ018TAJU	DX 2X2 CEILING CASSETTE	CLASSROOM 204	405	18,000/ 13,000	17,000	208-230/1/60	0.4	36.4	1,2

NOTES:

1. PROVIDE MANUFACTURER RECOMMENDED PROGRAMMABLE THERMOSTAT CONTROLLER
2. PROVIDE MANUFACTURER RECOMMENDED GRILLE
3. PROVIDE ARCHITECT SELECTED GRILLE
4. PROVIDE HOUSEKEEPING PAD.
5. PROVIDE EQUIPMENT SUPPORT ROOF CURB.
6. PROVIDE CENTRAL CONTROLLER.

(I-TOUCH MANAGER) LCD DISPLAY,
TOUCH SCREEN, CAPABLE OF CONTROLLING ALL VRF SYSTEMS.
INCLUDE BACNET INTERFACE, IF ADDRESS REQUIRED BY OWNER.

TYPES:
DX = DIRECT EXPANSION 4410A

Innovative Engineering Services, LLC
Casey J. Eng. & Associates
131 E. Main St., Suite 100
Pawcatuck, CT 06460
TEL: 203-467-4378 FAX: 203-795-7729

PAWCATUCK MIDDLE
SCHOOL MASTER PLAN
49 NORTH STONINGTON ROAD
OLD MYSTIC, CT

SCALE:
PROJ. NO.:
REF. DWG. NO.:
REF. DWG. REV.:

N.T.S.
19099
M3.00 DWG

DRAWN BY:
CHECKED:
ISSUED:
REVISED:

KL
AK
01/10/20
SKM-1